

DOSAGES REQUIRED TO CHEMICALLY TREAT 10,000 GALLONS OF WATER

<u>PARAMETER – CHEMICAL</u>	<u>REQUIRED DOSAGE</u>		
<u>FREE CHOLORINE</u>	<u>1 ppm</u>	<u>5ppm</u>	<u>10ppm</u>
Calcium Hypochlorite	2 oz	10 oz	20 oz
Sodium Hypochlorite – Bleach	13 fl oz	½ gal	1 gal
Dichlor	2 ½ oz	12 ½ oz	25 oz
Trichlor	1 ½ oz	7 ½ oz	15 oz
Chlorine gas	1.3 oz	6 ½ oz	13 oz
<u>NEUTRALIZE CHLORINE</u>	<u>10 ppm</u>	<u>50 ppm</u>	<u>100 ppm</u>
35% Hydrogen Peroxide	26 fl oz	1 gal	2 gal
Sodium Sulfite	2 lb	10 lb	20 lb
Sodium Thiosulfate	10 oz	3 lb	6 lb
<u>INCREASE TOTAL ALKALINITY</u>	<u>10 ppm</u>	<u>50 ppm</u>	<u>100 ppm</u>
Sodium Bicarbonate	1 ½ lb	7 ½ lb	15 lb
<u>INCREASE CALCIUM HARDNESS</u>	<u>10 ppm</u>	<u>50 ppm</u>	<u>100 ppm</u>
Calcium Chloride 77%	1 ¼ lb	6 ¼ lb	12 ½ lb
Calcium Chloride 100%	1 lb	5 lb	10 lb
<u>INCREASE STABILIZER</u>	<u>5 ppm</u>	<u>10 ppm</u>	<u>50 ppm</u>
Cyanuric Acid	6 ½ oz	13 oz	4 lb
Dichlor	13 oz	26 oz	not rec.